

98553

WATER WELL REPORT

Start Card No. W148886  
 Unique Well I D # AGW079  
 Water Right Permit No

STATE OF WASHINGTON

(1) OWNER: Name LESLIE JANICE P (01629) Address 72 STAATS RD WHITE SALMON, WA 98672-

(2) LOCATION OF WELL: County KLIKITAT - SW 1/4 SW 1/4 Sec 12 T 4 N, R 11E WM  
 (2a) STREET ADDRESS OF WELL (or nearest address) 72 STAATS RD, WHITE SALMON WA

(3) PROPOSED USE: DOMESTIC

(4) TYPE OF WORK: Owner's Number of well 1  
 (If more than one)  
 Method: ROTARY  
 NEW WELL

(5) DIMENSIONS: Diameter of well 6 inches  
 Drilled 435 ft Depth of completed well 435 ft

(6) CONSTRUCTION DETAILS:  
 Casing installed: 6" Dia. from +1 ft. to 59 ft.  
 WELDED " Dia from ft. to ft.  
 " Dia from ft. to ft.

Perforations: NO  
 Type of perforator used  
 SIZE of perforations in. by in.  
 perforations from ft to ft.  
 perforations from ft. to ft.  
 perforations from ft to ft.

Screens NO  
 Manufacturer's Name  
 Type Model No.  
 Diam. slot size from ft to ft.  
 Diam slot size from ft to ft

Gravel packed: NO  
 Gravel placed from ft. to ft. Size of gravel

Surface seal: YES To what depth? 20 ft.  
 Material used in seal CEMENT & BENTON  
 Did any strata contain unusable water? NO  
 Type of water? Depth of strata ft  
 Method of sealing strata off

(7) PUMP: Manufacturer's Name  
 Type H P

(8) WATER LEVELS: Land-surface elevation  
 above mean sea level ft  
 Static level 290 ft. below top of well Date 07/19/01  
 Artesian Pressure lbs. per square inch Date  
 Artesian water controlled by

(9) WELL TESTS: Drawdown is amount water level is lowered below static level  
 Has a pump test made? NO If yes, by whom?  
 Yield gal./min with ft drawdown after hrs

Recovery data  
 Time Water Level Time Water Level Time Water Level

Date of test  
 Bailer test gal./min. ft. drawdown after hrs  
 Air test 30 gal./min. w/ stem set at 425 ft for 1 hrs  
 Artesian flow g p.m Date  
 Temperature of water Was a chemical analysis made? NO

(10) WELL LOG

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change in formation.

MATERIAL	FROM	TO
TOP SOIL	0	2
BROWN CLAY	2	14
BROWN BASALT, MEDIUM	14	50
GRAY BASALT, MEDIUM HARD	50	86
GRAY BASALT, HARD	86	198
GRAY BASALT, MEDIUM HARD	198	220
GRAY BASALT, POROUS, WHITE SEAMS	220	246
GRAY BASALT, MEDIUM HARD	246	290
GRAY BASALT, POROUS, MEDIUM HARD	290	310
BROWN & GRAY BASALT, MEDIUM HARD	310	350
BROWN & GRAY BASALT, MEDIUM, WATER BEARING	350	376
GRAY BASALT, HARD	376	421
BROWN & GRAY BASALT, HARD, WATER BEARING	421	435



Work started 07/17/01 Completed 07/19/01

WELL CONSTRUCTOR CERTIFICATION:  
 I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief

HANE M-X DRILLING CO.  
 (Person, firm, or corporation) (Type or print)

ADDRESS BOX 470 DALLESPORT, WA

[SIGNED] *[Signature]* License No. 833 & 834 & 973

Contractor's  
 Registration No. WEDRIC134PB Date 07/23/01